Bi weekly Field Report

Surveyor Date visited


Time visited

Zaw La 22 Mar 2019 15:40 am

Weather Condition Sunny
The last time of heavy raining:

No	Item	Condition	Narrative Description and Photos	
1	(1.1) Water Supply System	Improved □ Same •* Worse □ *as last week	Narrative Description Water distribution system has been supporting ninety household of the zone B resettled families. The new well was drilled and installed the pipe line and its necessary instruments because the underground water of the previous well includes iron hydroxide and yellowish mud that clogged in the iron removal tank. The current water condition is quite good and no iron hydroxide and yellowish mud are found.	
			Photos	
			Water from ground water tank	Ping line distribution water to house
			Water from ground water tank	Pipe line distribution water to houses

No	Item	Condition	Narrative Description and Photos	
1	(1.2) Well	Improved□ Same ■* Worse □ *as last week	Water from two open-wells is c living. There are eleven tube wel the water basically from the pip frequency of water usage from t	clean enough to use for drinking and ls in the relocation site. Residents use beline distribution system so that the he tube wells is very low. To sustain wells, the leg pumps were kept and aps till the residents use.
			Open Well No. 1	Open Well No. 2
	(2) Drainage	Improved□ Same ■* Worse □ *as last week	The drain at the corner of Main Road A and B The exit of the drain at the corner of Site village road and 3 rd street	The exit of the drain at the corner of Site village road and 2 nd street The exit of the drain at the corner of Site village road and Main Road C
	(3) Road	Improved□ Same © *	All the roads are getting dry are	nd no problem for walking.
		Worse □	<u>Photos</u>	



		7 th Street	Site Village
(4) Garbage Condition	Improved□ Same ■* Worse □ *as last week	of each road until the end of Apri are kept by the community leader near the triangle junction of Main	e bins are provided. been provided and placed at the corner l. After April 2018, all the garbage bins of PAPs in the communal compound a Road C and Upper Fourth Street. But e truck from township municipal office
		Rubbishes in the creek near 1st street	Rubbishes in the creek near 2nd street
		The soil was filled near the creek of Main Road C in March	The soil was filled near the creek of 6 th Street in March

(5) Fly
proof
toilet

Improved□ Same •* Worse □ *as last week

- All of the fly proof toilets are used the residents.
 - All of the toilets are repaired by the following procedures;
 - Installation the extra septic tanks beside the original
 - The pipe line system is installed from the extra tank to the ditch to flow the liquid out.

The toilet renovation plan was successfully done and there is no problem at the moment.

	No. of H	No. of HHs		
Condition	This week condition	Previous		
		week condition		
Level 1	91	91		
Level 2	0	0		
Level 3	0	0		
Level 4	0	0		
No Toilet	0	0		

<Evaluation Criteria>

Level 1

- Fly proof toilet is not needed to be repaired.
- No/rarely toilet unavailable

Level 2

- Fly proof toilet is needed to be repaired.
- Rarely toilet unavailable

Level 3

- Fly proof toilet is needed to be repaired.
- Often toilet unavailable
- As the result of filling the soil and also due to the heavy rain, some toilets are inconvenience to use.

Level 4

- Fly proof toilet is urgently needed to be repaired.
- Often toilet unavailable

Photos









	(6) Electricity	Improved□ Same ■* Worse □ *as last week	 Residents get the electricity regularies Electric poles and transformer are foundations. There are some pieces of wood ur and it's needed to clean up. Photos Transformer No. 1 	
No	Item	Condition	Description	
2	(1)House Construct- ion	No. of houses which are not completed (4)	 are owned by father and son. Co houses and one house is not finish Plot No.64, the house construction Plot No.78, the house construction PAPs are living now. Plot No. 66, the house construction and the second floor is still needed. 	on seems to be stopped. In is needed to be carried on, however on for the first floor has been finished
			Photos House No. 9	House No. 64





3 Other Issues

(1). Drainage condition for rain water in the compounds

Description

	No. of HHs	
Condition	This week	Previous week
	condition	condition
Level 1	85	85
Level 2	6	5
Level 3	0	0
Level 4	0	1

<Evaluation Criteria>

Level 1

-No mud and no standing water with their own drainage system in their compound

Level 2

-No mud and no standing water in their compound

Level 3

- Some or little mud and standing water in their compound

Level 4


-A lot of mud and standing water in their compound

Photos











(2) Plantation

In front of the compounds, the shady trees, fruit trees, flowering plants and vegetables are being planted.

Description

- In front of the compounds, the shade trees, fruit trees, flowering plants and vegetables are being planted.

Type	No. of HHs	Remarks
Shade tree	15	Albizzia, Indian almond, Neem tree, etc. HH No. 20, 40, 43, 48, 51, 57, 59, 61, 62, 67, 69, 72, 73, 77, 85
Fruit tree	37	Banana, Mango, sugar cane, coconut, citrus and jack fruit etc. HH No. 3, 15, 17, 20,21, 23, 28, 30, 31, 32, 34, 37, 40, 41, 48, 51, 52, 55, 57, 58, 59, 61, 62, 63, 67, 68, 70, 71, 72, 73, 77, 78, 82, 85, 86, 88
Vegetables	20	Chili, tomato, bitter gourd, Roselle, gourd, basils, eggplant etc. HH No. 12, 17, 21, 41, 49, 58, 59, 61, 62, 63, 67, 68, 70, 71, 72, 73, 77, 82, 85, 86
Flowering plant	31	Jasmine, poinsettia, orchid, kiss me quick, etc. HH No. 3, 5, 6, 8, 10, 12, 13, 14, 17, 20, 21, 22, 23, 29, 30, 31, 32, 46, 48, 58, 59, 61, 62, 65, 67, 68, 69, 72, 77, 78, 86

Photos,









(3) Livestock

Description

-The chicken, gooses and ducks are being raised.		
No. of HHs	Remarks	
6	HH No. 13, 14, 21,	
	59, 67, 78	
3	HH No.12	
2	HH No. 40, 67	

Photos



